

**From:** Garnand, Cathleen  
**Sent:** Thursday, January 25, 2018 3:40 PM  
**To:** Eady, Dana  
**Subject:** FW: Technical Report from County of Santa Barbara - Response to Water Board audit

Dana,

The email from the Central Coast Water Board, below, confirms that the County's response to the Notice of Violation letter (6/1/2017) was sufficient to demonstrate that the Golden Inn meets the necessary performance requirements for stormwater runoff.

There were other items in the letter, unrelated to Golden Inn, that we are working on.

However, Golden Inn is completed.

**Cathleen Garnand** | Interim Manager  
Project Clean Water | Water Resources Division  
SANTA BARBARA COUNTY - PUBLIC WORKS DEPARTMENT  
123 East Anapamu Street, Santa Barbara CA 93101  
Main: 805.568.3440 | Direct: 805.568.3561  
[www.sbprojectcleanwater.org](http://www.sbprojectcleanwater.org)  
[cgarnan@co.santa-barbara.ca.us](mailto:cgarnan@co.santa-barbara.ca.us)

---

**From:** Sharkey, Lucas@Waterboards [mailto:Lucas.Sharkey@waterboards.ca.gov]  
**Sent:** Thursday, January 25, 2018 2:42 PM  
**To:** Garnand, Cathleen  
**Cc:** Roques, Dominic@Waterboards  
**Subject:** RE: Technical Report from County of Santa Barbara - Response to Water Board audit

Cathleen,

I apologize for the delay in responding. We have reviewed your technical report for responses to the requested Actions in the June 1, 2017 Notice of Violation and Technical Report Order.

The County has taken sufficient corrective action related to the Golden Inn & Village development project, such that the site appears to meet the Performance Requirements of Resolution No. R3-2013-0032 (Central Coast PCRs). The plugs in the 4-inch perforated PVC pipe outlets from the detention basins allow for sufficient retention capacity so the site meets Performance Requirement 3 of the PCRs. The updated measurements of storage in the basins, and updated peak runoff calculations for the 2- through 10-yr peak flows, show there is sufficient reduction in peak flows leaving the development site to meet Performance Requirement 4 of the PCRs.

There is additional information that Central Coast Water Board staff requested related to the single family residence cited in Violation 1, and related to the SWPPP for Deficiency 2. The County's responses to this information will be evaluated at a later date.

I appreciate your responsiveness and look forward to reviewing the SWPPP and additional information you plan to provide.

~ Lucas

=====  
**Lucas J. Sharkey, P.E.** | Water Resource Control Engineer  
Central Coast Water Board | 895 Aerovista Place, Suite 101 | San Luis Obispo, CA 93401  
P: (805) 594-6144